

Construction Products Regulation 2011: Declaration of Performance (DoP)

CPR Nr. 305/2011 (EU)

DoP Number: ZDP-MOL-001-EU

CE Certificate of Conformity Number: AG0236

- **Unique identification code of the product-type:** ZTLKA64, ZTLKA76 Series Mortice Tubular Latch
- **Intended use or uses:** Fire and smoke compartmentation doors, to fulfil self-closing requirements
- **Name of manufacturer:** ERA Home Security Ltd Trading as Zoo Hardware, Unit B, Dukes Drive, Kingmoor Park North, Cumbria, Carlisle, CA6 4SH
- **EU representative:** SchlegelGiesse, Giesse S.p.A., Via Tubertini G,1, 40054 Budrio, Bologna, 295136 Italy
- **System of assessment product as set out in CPR, Annex V:** System 1
- **Harmonised standard:** EN12209: 2003/AC: 2005
- **Notified body:** 2812 Element Materials Technology, Rotterdam B.V.

Declared Performance:

Essential Characteristic	Performance:	Harmonised Technical Specification:
Self Closing	-Closing force: Pass (Grade 7) -Re-latching force of latch bolt: Pass (>2.5N)	EN12209: 2003/AC:2005
Durability of Self Closing	-Durability of self closing: Pass (Grade C)	
Ability to maintain the door in the closed position and not contribute to its spread of fire	- Pass (Grade 1)	
Control of dangerous substances	The materials in the product/s do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	

Signed for and on behalf of the manufacturer by:



Ben Penson
Technical, Innovation and Development Director
ERA Home Security Ltd

Date of First Issue: **2/6/2022**

Updated: **29/11/2022**